

COUNTY OF EL DORADO

DEPARTMENT OF TRANSPORTATION




CONSTRUCTION DIVISION
 2441 Headington Road
 Placerville CA 95667
 Phone: (530) 642-4987
 Fax: (530) 295-2655

JAMES W. WARE, P.E.
 Director of Transportation

 Internet Web Site:
<http://edcgov.us/dot>

MAIN OFFICE
 2850 Fairlane Court
 Placerville CA 95667
 Phone: (530) 621-5900
 Fax: (530) 626-0387



DATE: July 13, 2011

TO: All Prospective Bidders

SUBJECT: Response to Bidders' Inquiries No. 2
 Contract Overlay - North Shingle Road (4 miles) Project
 (Contract No. PW 10-30567, CIP No. 72179)

ITEM NO.	LOCATION, PAGE OR DRAWING NO.	DESCRIPTION OF CHANGE
2.01	SP- 42	<p>Question: Section 10-1.12 Has the County already identified the areas of the existing pavement that do not meet the straight test or will the contractor be responsible for profilographing the existing road way to determine the areas that do not meet the straight test?</p> <p>Answer: See the second paragraph of Section 10-1.12 "Rubberized Hot Mix Asphalt (Gap Graded).</p>
2.02	SP-7 and SP-37	<p>Question:</p> <p>1) Section 4-1.01 - will the Job Mix Formula be approved prior to the start of the 30 calendar day completion time?</p> <p>2) Section 4-1.01 and Section 10-1.09 - will the 30 day completion time include the placement of the portable changeable message signs 7 days prior to the start of the project?</p> <p>Answer:</p> <p>1) The answer to this question depends on when the Contractor submits the Job Mix Formula to the County. If it is submitted sufficiently before the start date of the contract days stated in the Notice to Proceed, it is conceivable that the Job Mix Formula could be approved prior to the start of the 30 calendar days. Otherwise the answer is no.</p> <p>2) Yes</p>

Page 2 of 2
Contract Overlay – North Shingle Road (4 miles) Project
Contract No. 10-30567, CIP No. 72179
Response to Bidders' Inquiries No. 2
July 13, 2011

Holders who have already mailed their proposal can contact Janel Gifford at (email: Janel.Gifford@edcgov.us) to arrange return of their proposal.

Inform all suppliers and subcontractors as necessary.

The DOT is only sending this Response to Bidders' Inquiries by posting on the following website: <http://www.edcgov.us/Government/DOT/Bids.aspx>.

Responses to bidder inquiries, unless incorporated into formal addenda to the contract, are not a part of the contract, and are provided for the bidder's convenience only. In some instances, the question and answer may represent a summary of the matters discussed rather than a word-for-word recitation. The availability or use of information provided in the responses to bidder inquiries is not to be construed in any way as a waiver of the provisions of Section 2-1.03, "Examination of Plans, Specifications, Contract, and Site of Work," of the Standard Specifications or any other provision of the contract, the plans, Standard Specifications, or special provisions, nor to excuse the contractor from full compliance with those contract requirements. Bidders are cautioned that subsequent responses or contract addenda may affect or vary a response previously given.

Sincerely,



Janel Gifford, P.E.
Senior Civil Engineer
Office Engineer/Contract Services Unit